



**NOTES:**

1. MAXIMUM CHIMNEY HEIGHT SHALL BE 12".
2. MANHOLES SHALL BE CONCENTRIC UNLESS OTHERWISE APPROVED BY THE CITY ENGINEER.
3. TRANSITIONS TO 5' AND 6' BARREL DIAMETERS SHALL OCCUR JUST BELOW THE CONE SECTION.
4. INVERTS SHALL BE EQUAL TO OR GREATER THAN THE PIPE DIAMETER.



**CITY OF  
DECATUR**

**SEWER SYSTEM CONSTRUCTION DETAILS  
PRECAST SANITARY SEWER  
MANHOLE**

REVISED MAR 2000

SCALE: 1/2" = 1'

SHEET: S-2